



8" X 6" FLANGE TEE,  
8" FLANGE X M.J. ADAPTER,  
AND 8" BLIND FLANGE

ABANDON EXISTING  
WHARF HEAD FIRE  
HYDRANT

EXISTING CAP. TIE-IN WITH 8"  
TRANSITION COUPLING AND  
APPROXIMATELY 24' OF PVC  
PIPE.

6" FLG X M.J. G.V.

PROPOSED FIRE  
HYDRANT LOCATION

LIST OF MAJOR QUANTITIES:

- (1) 8" TRANSITION COUPLING
- (24') 8" C900 CLASS 150 PVC PIPE
- (1) 8" X 6" FLANGE TEE
- (1) 8" FLANGE X MJ ADAPTER
- (1) 8" BLIND FLANGE
- (1) 6" M.J. X FLG. GATE VALVE.
- (1) CHRISTY G5 VALVE BOX AND LID
- (4') 8" SDR 35 PVC PIPE
- (7') 6" C900 CLASS 150 PVC PIPE
- (1) 6" MJ HYDRANT BURY
- (1) BREAK-OFF SPOOL
- (1) JONES J-3740 FIRE HYDRANT

CONCRETE AS NEEDED FOR 3' X 3' PAD

PROJECT SCOPE:

ABANDON EXISTING WHARF HEAD FIRE HYDRANT ON 4" STEEL MAIN. TIE-IN TO 8-INCH MAIN AND INSTALL ONE JONES J-3740 STEAMER FIRE HYDRANT IN THE CENTER MEDIAN PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATIONS SECTION 307.05 & STD. PLANS S-9 & S-10. APPROXIMATE RUN: 7 FT.

CONTRACTOR TO CALL U.S.A. TO MARK LOCATIONS OF ALL UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION.

EXACT FIRE HYDRANT LOCATION TO BE DETERMINED IN THE FIELD BY DISTRICT INSPECTOR PRIOR TO CONSTRUCTION.

G:\01\_Proj\_Current\02-43\Draw\Rev\_A\A-2.dwg 2-02-04 09:50:25 AM carolc

EXISTING	PROPOSED	LEGEND	
		GATE VALVE	
		BUTTERFLY VALVE	UTILITY POLE MANHOLE (4' DIA. TYP.)
		REDUCER	STORM DRAIN INLET
		FIRE HYDRANT	
		BLOW-OFF	UTILITY BOX
		TRANSITION COUPLING OR FCA	PROPOSED WATER MAIN
		TEE OR CAP	(E) WATER MAIN
		ENDCAP	
		FLG. OR M.J. FITTING	

**SOQUEL CREEK  
WATER DISTRICT**

P.O. Box 158 Soquel, California 95073  
Phone Number: (831) 475-8500  
Fax Number: (831) 475-4291  
DWG. NO. A-04-2133-H

CWO NO. 02-43	PJT. NAME: F.H. UPGRADE 303 ESTRELLA AVE., LSB	REV A
SCALE: 1"=20'	DWN BY: CCC	SHEET: 2 OF 2