



5180 SOQUEL DR.
PO BOX 158
SOQUEL, CA 95073
TEL 831-475-8500
FAX 831-475-4291

BOARD OF
DIRECTORS

DANIEL F. KRIEGE
President
JOHN W. BEEBE
Vice President

GARY E.
HAZELTON
BRUCE DANIELS
Dr. BRUCE JAFFE

To: **Plan Holder**

Attn.: **Bidder**

Date: **December 19, 2002**

Project: **Rosedale and Tannery Filter
and Reaction Vessel
Recoating**

CWO No.: **03-119**

Addendum No. 1

The District has consulted with a qualified coating inspection firm to obtain additional information regarding the existing condition of the vessels and make recommendations regarding recoating. The coating inspector informed the District of the following: the existing coating consists of alkyd; power washing can be used to prepare the existing coating; a revised coating material can be used; and, samples of the existing coating are being tested for metals. Coating sample results will be provided prior to the deadline for bid submittal. Specifications are amended for degree of preparation and coating materials to be used. Contract documents for the project are changed as follows:

1. Section 504.11 (Preparation) is amended as follows:
 - a. Power wash at 3000 p.s.i. minimum, using Devoe devprep #88 until all chalking is removed.
 - b. Hand and power tool clean as per SSPC/SP# 2&3 all rusted or peeling areas, All edges to be sanded to a smooth transition.
 - c. For areas of lead, tools will have vacuum attachments using HEPA Vacuums.
 - d. Cleaner Type: Devoe Devprep #88
2. Section 504.12 (Application) is amended as follows:
 - a. Spot prime all repaired areas 2.0 to 4.0 mils.
 - b. Apply full prime @ 3.0 to 5.0 mils.
 - c. Spot prime and prime coat: Devoe #235-Ameron Amerlock #400-Carboline Carbomastic #15.
 - d. Apply full finish @ 2.0 to 4.0 mils.
 - e. Finish coat: Devoe #379-Ameron Amershield-Carboline #134.

All other relevant provisions and specifications regarding the project apply. Those items which conflict with the District's intent to power wash and overcoat with the revised material as specified, will not apply. Any questions regarding conflicting specifications shall be directed to the District Engineer in writing.

BID DATE REMAINS: Tuesday, January 28, 2003 AT 2:00 PM

Please adjust bids accordingly. If you would like a hard copy of this addendum, you may pick one up at the District Office, 5180 Soquel Drive, Soquel, CA 95073.

Bidder acknowledges receipt of this addendum, which shall be attached to and made a part of the proposal.

Contractor Representative

Date

Soquel Creek Water District
Jeffery N. Gailey, PE
Engineering Manager/ Chief Engineer