



5180 SOQUEL DR.  
PO BOX 158  
SOQUEL, CA 95073  
TEL 831-475-8500  
FAX 831-475-4291

BOARD OF  
DIRECTORS

To: **Plan Holder**

Project: **Country Club Well Power  
Service Upgrade**

BRUCE DANIELS  
President  
Dr. THOMAS LAHUE  
Vice President

Attn.: **Bidder**

CWO No.: **03-139**

Date: **Nov. 18, 2005**

DANIEL F. KRIEGE  
JOHN W. BEEBE  
Dr. BRUCE JAFFE

**Addendum No. 1**

---

The contract documents for the project have been changed as follows:

- The Contractor shall provide and install sixty (60) lineal feet of 5” plastic conduit, in compliance with requirements of PG&E.
- All conduit shall be Schedule 80 PVC conforming with the provisions of UL651 and NEMA and NEC standards.
- The Contractor shall provide and install one (1) underground conduit riser stub at the base of the existing utility pole located in front of the District owned parcel.

**The Bid Date has been changed to December 20, 2005 at 2 p.m.**

Please adjust bids accordingly. If you would like a hard copy of this addendum, you may pick one up at the District Office, 5180 Soquel Drive, Soquel, CA 95073.

Bidder acknowledges receipt of this addendum, which shall be attached to and made a part of the proposal.

---

Contractor Representative

Date

---

Soquel Creek Water District  
Jeffery N. Gailey, PE  
Engineering Manager/ Chief Engineer