



5180 SOQUEL DR.
PO BOX 158
SOQUEL, CA 95073
TEL 831-475-8500
FAX 831-475-4291

BOARD OF
DIRECTORS

BRUCE DANIELS
President
Dr. THOMAS LAHUE
Vice President

DANIEL F. KRIEGE
JOHN W. BEEBE
Dr. BRUCE JAFFE

To: **Plan Holder**

Attn.: **Bidder**

Date: **Dec. 16, 2005**

Project: **Country Club Well Power
Service Upgrade**

CWO No.: **03-139**

Addendum No. 3

The contract documents for the project have been changed as follows:

- Addendum 1 incorrectly stated the lineal footage of 5" PVC conduit. The correct amount the Contractor shall provide is one-hundred (100) lineal feet of 5" diameter PVC conduit, in compliance with requirements of PG&E.

The Bid Date remains December 20, 2005 at 2 p.m.

Please adjust bids accordingly. If you would like a hard copy of this addendum, you may pick one up at the District Office, 5180 Soquel Drive, Soquel, CA 95073.

Bidder acknowledges receipt of this addendum, which shall be attached to and made a part of the proposal.

Contractor Representative

Date

Soquel Creek Water District
Jeffery N. Gailey, PE
Engineering Manager/ Chief Engineer