

INSTALL 2 COMPARTMENT (1000/2000 GAL.)
U/L-285 ABOVE GROUND VAULT TANK.
CONTAINMENT SOLUTIONS OR APPROVED
EQUAL.

"ECONOMICAL" DISPENSERS (2) FROM
CONTAINMENT SOLUTION OR APPROVED EQUAL
(SEE CUT SHEETS PROVIDED IN SPECS.)

TRAFFIC BOLLARDS—SEE DETAIL SHEET B-3
PERMANENT TYPE (11)
REMOVABLE TYPE (3)

AC BERM SEE DETAIL
SHEET B-1

1000 GALLON
DIESEL

2000 GALLON
UNLEADED

6" THICK REINFORCED
CONCRETE WASH AREA

6" CL2 BASEROCK
@ 95% R.C.

EXISTING CONCRETE
SLAB

8" CL2 BASEROCK (BENEATH
TANK FOUNDATION ONLY)
@ 95% R.C.

PROVIDE HOLD DOWNS
PER MANF. SPECS.

NATIVE MATERIAL
(RECOMPACT TO 90% R.C. IN ONE 2FT LIFT)

SEE FOUNDATION DETAIL SHEET B-3

SECTION B-B

No.	Revision/Issue	Date
A	ISSUED FOR APPROVAL	11/18/03
0	ISSUED FOR CONSTRUCTION	11/18/03

HEADQUARTERS ABOVE GROUND
FUEL TANK INSTALLATION

SOQUEL, SANTA CRUZ COUNTY, CALIFORNIA
APN: 030-242-43
c:\01_Proj_Current\03-144\3rd_time_out_to_bld\Rev_0\B-3.dwg 11-18-03 01:21:27 PM tgd

SOQUEL CREEK
WATER DISTRICT
PO Box 158 Soquel, California 95073
Phone Number: (831) 475-8500
Fax Number: (831) 475-4291

REVIEWED BY:
O.S.M.
DATE

CWO. NO. 03-144
DATE: 10/20/03
SCALE: 3/8"=1'
DESIGN BY: TAD

SHEET
B-3

DWG. NO. B-03-2121-H



Jeffery N. Gailey
Chief Engineer
Engineering Manager