

MATCHLINE—SEE SHEET D-5

MATCHLINE—SEE SHEET D-5

INSTALL:
1-JONES J3740 FIRE HYDRANT
PER SCWD STANDARD PLANS
S-9 & S-10. EXACT LOCATION
TO BE DETERMINED IN THE FIELD
BY DISTRICT INSPECTOR.

RECONNECT EXISTING 2"
FIRE AND DOMESTIC
COMBINED SERVICE.

RECONNECT EXISTING 2"
FIRE AND DOMESTIC
COMBINED SERVICE.

RECONNECT EXISTING 2"
FIRE AND DOMESTIC
COMBINED SERVICE.

ABANDON EXISTING WHARF
HEAD FIRE HYDRANT

ABANDON EXISTING 2"
STL. MAIN.

INSTALL IN-LINE VALVE

TIE-IN 14 AT BAYVIEW DR.:
INSTALL:
1-6" TRANS COUPLING
1-6" G.V., M.J.
TIE INTO EXISTING 6" AC
MAIN
1-JONES J-3740 FIRE
HYDRANT
1-ABANDONMENT OF
EXISTING WHARF HEAD FIRE
HYDRANT
1-TEMPORARY 2"
BLOW-OFF

RIM= 114.8
INV= 105.3
INV= 105.2, E

RIM= 112.6
INV= 105.48

No.	Revision/Issue	Date
A	ISSUED FOR APPROVAL	04/01/03
0	ISSUED FOR CONSTRUCTION	04/01/03

BAYVIEW DR. MAIN REPLACEMENT

APTOS, SANTA CRUZ COUNTY, CALIFORNIA
APN: N/A

SOQUEL CREEK WATER DISTRICT
 PO Box 158 Soquel, California 95073
 Phone Number: (831) 475-8500
 Fax Number: (831) 475-4291

CWO. NO. 03-146
DATE: 10/8/02
SCALE: 1"=20'
DESIGN BY: TAD
DWG. NO. D-03-2120-F

Certification:
 REGISTERED PROFESSIONAL ENGINEER
 JEFFERY N. GAILEY
 No. 47298
 Exp. 12/31/03
 CIVIL
 STATE OF CALIFORNIA

Jeffery N. Gailey
Chief Engineer
Engineering Manager

SHEET:
D-6

