



SSMH
 R 133.3
 I 126.87
 I 126.77, E

8" x 6" FLG
 TAPPING
 SLEEVE

6" FLG X
 M.J. G.V.

45° ELBOW
 M.J.

WATER
 METER

J-POLE

BOLLARD

PROPOSED
 FIRE
 HYDRANT
 LOCATION

LIST OF MAJOR QUANTITIES:

- (1) 8" x 6" TAPPING SLEEVE
- (1) 6" M.J. X FLG. GATE VALVE.
- (1) CHRISTY G5 VALVE BOX AND LID
- (4') 8" SDR 35 PVC PIPE
- (1) 6" MJ HYDRANT BURY
- (1) BREAK-OFF SPOOL (SIZE HEIGHT TO MATCH EXISTING GRADE)
- (1) JONES J-3740 FIRE HYDRANT
- (1) 4" GIP TRAFFIC BARRIER W/ POST CAP
- (1) 6" 45°ELBOW, M.J.

CONCRETE AS NEEDED FOR 3' X 3' PAD

CONTRACTOR TO CALL U.S.A. TO MARK LOCATIONS OF ALL UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION.

EXACT FIRE HYDRANT LOCATION TO BE DETERMINED IN THE FIELD BY DISTRICT INSPECTOR PRIOR TO CONSTRUCTION.

FIRE HYDRANT BURY FLANGE TO BE SET AT EXISTING EOP ELEVATION. ADD NECESSARY BREAK OFF SPOOL TO MATCH EXISTING GRADE.

PROJECT SCOPE:

HOT TAP AND INSTALL ONE JONES J-3740 STEAMER FIRE HYDRANT PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATIONS SECTION 307.05 & STD. PLANS S-9 & S-10. APPROXIMATE RUN: 25 FT.

G:\01_Proj_Current\04-02\Draw\Rev_A\A-2.dwg 7-31-03 01:32:03 PM carolc

EXISTING	PROPOSED	LEGEND	
		GATE VALVE	
		BUTTERFLY VALVE	UTILITY POLE MANHOLE (4' DIA. TYP.)
		REDUCER	STORM DRAIN INLET
		FIRE HYDRANT	GAS VALVE
		BLOW-OFF	UTILITY BOX
		TRANSITION COUPLING OR FCA	PROPOSED WATER MAIN (E) WATER MAIN
		TEE OR CAP	
		ENDCAP	
		FLG. OR M.J. FITTING	

**SOQUEL CREEK
 WATER DISTRICT**

P.O. Box 158 Soquel, California 95073
 Phone Number: (831) 475-8500
 Fax Number: (831) 475-4291
 DWG. NO. A-04-2125-H

CWO NO. 04-02	PJT. NAME: F.H. INSTALLATION 423 HILLCREST DR., APTOS	REV A
SCALE: 1"=20'	DWN BY: CCC	SHEET: 2 OF 2