



SSMH
R 81.76
I 76.5, E,W
I 74.0

PROPOSED
FIRE
HYDRANT
LOCATION

6" FLG X
M.J. G.V.
6" TAPPING
SLEEVE

- LIST OF MAJOR QUANTITIES:
- (1) 6" TAPPING SLEEVE
 - (1) 6" M.J. X FLG. GATE VALVE.
 - (1) CHRISTY G5 VALVE BOX AND LID
 - (4') 8" SDR 35 PVC PIPE
 - (1) 6" MJ HYDRANT BURY
 - (1) BREAK-OFF SPOOL
 - (1) JONES J-3740 FIRE HYDRANT
 - (34') 6" C900 CLASS 200 PVC PIPE
 - CONCRETE AS NEEDED FOR 3' X 3' PAD

CONTRACTOR TO CALL U.S.A. TO MARK LOCATIONS OF ALL UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION.
EXACT FIRE HYDRANT LOCATION TO BE DETERMINED IN THE FIELD BY DISTRICT INSPECTOR PRIOR TO CONSTRUCTION.

PROJECT SCOPE:
HOT TAP AND INSTALL ONE JONES J-3740 STEAMER FIRE HYDRANT PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATIONS SECTION 307.05 & STD. PLANS S-9 & S-10. APPROXIMATE RUN: 34 FT.

G:\01_Proj_Current\04-06\Draw\Rev_A\A-2.dwg 8-20-03 01:09:29 PM Tajd

EXISTING	PROPOSED	LEGEND	
		GATE VALVE	
		BUTTERFLY VALVE	
		REDUCER	
		FIRE HYDRANT	
		BLOW-OFF	
		TRANSITION COUPLING OR FCA	
		TEE OR CAP	
		ENDCAP	
		FLG. OR M.J. FITTING	



**SOQUEL CREEK
WATER DISTRICT**

P.O. Box 158 Soquel, California 95073
Phone Number: (831) 475-8500
Fax Number: (831) 475-4291
DWG. NO. A-04-2126-H

CWO NO. 04-06	PJT. NAME: F.H. INSTALLATION 1550 LINCOLN AVE., CAPITOLA	REV A
SCALE: 1"=20'	DWN BY: CCC	SHEET: 2 OF 2