



PROJECT SCOPE:

HOT TAP AND INSTALL ONE JONES J-3740 STEAMER FIRE HYDRANT PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATIONS SECTION 307.05 & STD. PLANS S-9 & S-10. APPROXIMATE RUN: 7 FT.

CONTRACTOR TO CALL U.S.A. TO MARK LOCATIONS OF ALL UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION.

EXACT FIRE HYDRANT LOCATION TO BE DETERMINED IN THE FIELD BY DISTRICT INSPECTOR PRIOR TO CONSTRUCTION.

LIST OF MAJOR QUANTITIES:

- (1) 6" TAPPING SLEEVE
- (1) 6" M.J. X FLG. GATE VALVE.
- (1) CHRISTY G5 VALVE BOX AND LID
- (4') 8" SDR 35 PVC PIPE
- (1) 6" MJ HYDRANT BURY
- (1) BREAK-OFF SPOOL
- (1) JONES J-3740 FIRE HYDRANT
- (7') 6" C900 CLASS 200 PVC PIPE
- CONCRETE AS NEEDED FOR 3' X 3' PAD

G:\01_Proj_Current\04-27\Draw\Rev_A\A-2.dwg 1-29-04 09:47:59 AM carolc

EXISTING	PROPOSED	LEGEND	
		GATE VALVE	UTILITY POLE
		BUTTERFLY VALVE	MANHOLE (4' DIA. TYP.)
		REDUCER	STORM DRAIN INLET
		FIRE HYDRANT	GAS VALVE
		BLOW-OFF	UTILITY BOX
		TRANSITION COUPLING OR FCA	PROPOSED WATER MAIN (E) WATER MAIN
		TEE OR CAP	
		ENDCAP	
		FLG. OR M.J. FITTING	

**SOQUEL CREEK
WATER DISTRICT**

P.O. Box 158 Soquel, California 95073
 Phone Number: (831) 475-8500
 Fax Number: (831) 475-4291
 DWG. NO. A-04-2131-H

CWO NO. 04-27	PJT. NAME: F.H. INSTALLATION 4750 CRYSTAL ST., CAPITOLA	REV A
SCALE: 1"=10'	DWN BY: CCC	SHEET: 1 OF 2

