



STORM DRAIN DEPTH UNKNOWN, CONTRACTOR TO VERIFY DEPTH BEFORE STARTING WORK.

- LIST OF MAJOR QUANTITIES:**
- (2) 6" TRANSITION COUPLINGS
 - (10') 6" C900 CLASS 150 PVC PIPE
 - (1) PCC THRUST BLOCK
 - (1) 6" FLANGE TAPPING TEE
 - (1) 6" M.J. X FLG. GATE VALVE.
 - (1) CHRISTY G5 VALVE BOX AND LID
 - (4') 8" SDR 35 PVC PIPE
 - (1) 6" MJ HYDRANT BURY
 - (1) BREAK-OFF SPOOL
 - (1) JONES J-3740 FIRE HYDRANT CONCRETE AS NEEDED FOR 3' X 3' PAD AND CURB REPAIR

PROJECT SCOPE:
 ABANDON EXISTING WHARF HEAD HYDRANT, CUT OUT HYDRANT LATERAL AND TEE. REPLACE CUT SECTION OF MAIN WITH 6" C900 CLASS 150 PVC PIPE. HOT TAP 6-INCH MAIN TO INSTALL ONE JONES J-3740 STEAMER FIRE HYDRANT AS PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATIONS SECTION 307.05 & STD. PLANS S-9 & S-10. INSTALL THRUST BLOCK AS PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATION S-7. APPROXIMATE RUN: 4 FT.

CONTRACTOR TO CALL U.S.A. TO MARK LOCATIONS OF ALL UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION.

EXACT FIRE HYDRANT LOCATION TO BE DETERMINED IN THE FIELD BY DISTRICT INSPECTOR PRIOR TO CONSTRUCTION.

G:\01_Proj_Current\04-29\Draw\Rev_A\A-2.dwg 6-23-04 11:05:36 AM carolc

EXISTING	PROPOSED	LEGEND	
			UTILITY POLE
			MANHOLE (4" DIA. TYP.)
			STORM DRAIN INLET
			GAS VALVE
			UTILITY BOX
			PROPOSED WATER MAIN
			(E) WATER MAIN



P.O. Box 158 Soquel, California 95073
 Phone Number: (831) 475-8500
 Fax Number: (831) 475-4291
 DWG. NO. A-04-2134-H

CWO NO. 04-29	PJT. NAME: F.H. INSTALLATION 4175 COURT DR., SANTA CRUZ	REV A
SCALE: 1"=20'	DWN BY: CCC	SHEET: 2 OF 2