

State Park Drive

ABANDONED  
- "PAR 3"

Plant No. 12

Rotary Drilled, May 1959, Freedom Gen. Repair

Test Hole to 340 feet, well finished to 232 feet.

0 - 16 ft.	Sandy clay	
16 - 25 ft.	Sand and gravel	
25 - 48 ft.	Coarse sand and gravel	
48 - 58 ft.	Coarse gravel	
58 - 80 ft.	Clay	60' - 28" 1 1/2" ga.
80 - 115 ft.	Sand and gravel	Sanitary seal
115 - 138 ft.	Clay	50 sacks neat cement
138 - 226 ft.	Sand and gravel	
226 - 340 ft.	Clay	232 ft. -12" 8 ga.

Perforated 126 ft. to 226 ft. 36-1/8" x 3" sawed perf. per foot.

Tested (Murphy-Watsonville) about 80 GPM

SC-100 Used during initial test.

Tested again in 1961 (Farmers Merc.), about 80 GPM

Waltons used before second test. Great deal of drilling mud removed, but no increase in capacity.

<u>Date</u>	<u>Depth to bottom</u>	<u>Static Water Level</u>	<u>Pumping Water Level</u>	<u>GPM</u>
10/3/61	215 ft.	118 ft.		

Elev. above sea level

Length of pump 11/65