

DEMO TANK CONNECTION (E)
CONNECT TO VALVE (E)
INSTALL 12" FLEXIBLE COUPLING
PER DRAWING A-4

REMOVE/ABANDON
MAIN (E)

LIMITS OF CONSTRUCTION
AREA = 275 SF
SAWCUT= 90 LF

INSTALL ~35 LF
12" PVC MAIN
RESTRAIN ALL JOINTS

INSTALL 12" GATE VALVE
AT TEE (E)

4" STL

8" DRAIN LINE

12" CI

SOQUEL CREEK WATER DISTRICT

TANK SEISMIC RETROFIT PROJECT
CRESTLINE TANK

DATE 2/11/2005

DWN BY: AVW

SCALE 1"=10'

SHEET NO. A-1

