



LIMITS OF CONSTRUCTION
 AREA = 460 SF
 SAW CUT = 142 LF

REMOVE/ABANDON
 12" MAIN (E)

8" CMP
 OVERFLOW & DRAIN

INSTALL FLEXIBLE COUPLING
 PER DRAWING A-4
 CONNECT TO VALVE (E)

INSTALL ~70 LF OF
 12" PVC MAIN
 RESTRAIN ALL JOINTS

TIE IN 10" AC

GATE

PUMP
 BUILDING

10" C.I.

8" AC

CUT IN AND INSTALL
 12" GATE VALVE
 W/TIE-IN

SOQUEL CREEK WATER DISTRICT	
TANK SEISMIC RETROFIT PROJECT MAR VISTA TANK	
DATE 2/11/2005	DWN BY: AVW
SCALE 1"=10'	SHEET NO. A-2