



5180 SOQUEL DR.
PO BOX 158
SOQUEL, CA 95073
TEL 831-475-8500
FAX 831-475-4291

BOARD OF
DIRECTORS

To: **Plan Holder**

Project: **Park Wilshire Tank Recoat**

BRUCE DANIELS
President
Dr. THOMAS LAHUE
Vice President

Attn.: **Bidder**

CWO No.: **05-128**

Date: **September 1, 2005**

DANIEL F. KRIEGE
JOHN W. BEEBE
Dr. BRUCE JAFFE

Addendum No. 1

The contract documents for the **Park Wilshire Tank Recoat** project have been changed as follows:

- The Contract documents have been amended as shown on attached sheets.

Please adjust bids accordingly. If you would like a hard copy of this addendum, you may pick one up at the District Office, 5180 Soquel Drive, Soquel, CA 95073.

Bidder acknowledges receipt of this addendum, which shall be attached to and made a part of the proposal.

Contractor Representative

Date

A handwritten signature in black ink, appearing to read 'Jeffery N. Gailey', written over a horizontal line.

Soquel Creek Water District
Jeffery N. Gailey, PE
Engineering Manager/ Chief Engineer

Attached Sheets – 2 Pages

**Park Wilshire Tank Recoat
CWO 05-128**

Addendum No. 1

The following amendments to the contract documents are to be made (underlined text is to be added)

501.3 Protection of Property and Materials, amend Section A. as follows: ... at the District's direction. The District Engineer shall provide a list to the Contractor of homeowners to be notified, at least two days prior to start of work. The Contractor shall keep ...

501.3 Protection of Property and Materials, amend Section A. as follows: ... upon the completion of all work, at no additional cost to the District.

504.1 Scope, add Section G. as follows: At least two days prior to start of work, the Contractor shall arrange with the District for a pre-preparation conference at the job site to ensure that all parties are familiar with the entire project, including specifications and the manufacturers printed application instructions.

504.3 Submittals, add Section E.9. as follows: Thinner Addition – including maximum percent concentration allowable for potable water system applications.

504.3 Submittals, add Section G.6. as follows: Quantity of thinner used for each coat and total amount used.

504.4 Quality Assurance, amend Section A.2. as follows: The Contractor shall certify in writing that ...

504.4 Quality Assurance, amend Section G. as follows: The Contractor shall, at no cost to the District, provide a qualified technician ...

504.4 Quality Assurance, amend Section C. as follows: The District may, but is not required to monitor the quality ...

504.4 Warranty, amend Section G. as follows: ... the District may, at its option, retain another Contractor to perform the remedial work ...

504.11 Quality Control, add Section K.2. as follows: The District may, but is not required to also measure ...

504.11 Quality Control, add Section L.5. as follows: The District may hire a third party inspector to inspect contractor's work, but the ultimate responsibility for the quality of the Contractor's work and performance of contractual obligations remains with the contractor.

504.14 Preparation, amend Section A. as follows: ... in accordance with the coating manufacturer's instructions ...

**Park Wilshire Tank Recoat
CWO 05-128**

Addendum No. 1

504.15 Application, add Section C.4. as follows: The Contractor shall remove areas of paint in excess of allowable mils specified.

504.19 Reservoir Disinfection, add Sentence to Section A. as follows: Reservoir cleaning and disinfection shall not commence without written certification.

505.1 Scope, amend Section B. as follows: At least two days prior to start of work, the Contractor ...

505.3 Reference Standards, amend Section B. as follows: ... or this specification, however, the Contractor, not the District, is ultimately responsible for proper exterior coating application.

505.7 Safety, amend Section A. as follows: Safety and Health regulations and Industry Safety Standards.

505.13 Pre-Cleaning, amend Section as follows: The Contractor shall clean and make free of grease and oil (as per SSPC SP#1 solvent cleaning) all surfaces to be coated.

505.22 Inspection, Amend Section C. as follows: The Contractor shall indemnify, defend, and save harmless ...

505.22 Inspection, Amend Section E. as follows: ... the date of work performed, the relevant weather conditions, the type and amount ...

Move the entire Section 505.22, Inspection, to Section 506 as it is intended to apply to the entire recoating project including interior and exterior recoating application.