



5180 SOQUEL DR.
PO BOX 158
SOQUEL, CA 95073
TEL 831-475-8500
FAX 831-475-4291

BOARD OF
DIRECTORS

BRUCE DANIELS
President
Dr. THOMAS LAHUE
Vice President

DANIEL F. KRIEGE
JOHN W. BEEBE
Dr. BRUCE JAFFE

To: **Plan Holder**

Attn.: **Bidder**

Date: **January 24, 2006**

Project: **Fire Hydrant Installation at
1790 47th Ave.**

CWO No.: **06-25**

Addendum No. 1

The contract documents for the **Fire Hydrant Installation at 1790 47th Ave.** project have been changed as follows:

- The contract documents have been amended as shown on the attached sheet.

BID DATE REMAINS: Tuesday, February 7, 2006 AT 2:00 PM

Please adjust bids accordingly. If you would like a hard copy of this addendum, you may pick one up at the District Office, 5180 Soquel Drive, Soquel, CA 95073.

Bidder acknowledges receipt of this addendum, which shall be attached to and made a part of the proposal.

Contractor Representative

Date

Soquel Creek Water District
Jeffery N. Gailey, PE
Engineering Manager/ Chief Engineer

HYDRANT HEAD & B.O. SPOOL WITH BRONZE CAPS AND CHAIN PAINTED OSHA YELLOW WITH RUST-OLEUM 2143, DUPONT 23663D, AERVOE 302 OR KRYLON 1813. (PLASTIC CAPS NOT ALLOWED)

VALVE BOX ASSEMBLY PER SCWD STANDARD S-6.

BREAK-OFF SPOOL AND BREAK-OFF BOLTS.

SOLID BOLTS.

3' X 3' P.C.C. PAD

6" M.J. X FLG. G.V.,

6" FLG. TEE

M.J. HYDRANT BURY

4"

THRUST BLOCK PER SCWD STANDARD S-7 WHEN REPLACING HYDRANT ON AN EXISTING LATERAL.

6" D.I.P. OR C-900 PVC PIPE.

THRUST BLOCK PER SCWD STANDARD S-7 WHEN REPLACING HYDRANT ON AN EXISTING LATERAL.

NOTE:

1. HYDRANT SHALL BE COVERED WITH A BURLAP SACK UNTIL PUT IN SERVICE.
2. CONTRACTOR SHALL ENSURE PROPER THRUST RESTRAINT

MIRROR FITTINGS ON OTHER SIDE OF TEE

PROPOSED 6" X 4" FLG. REDUCER

PROPOSED 4" FLG. X M.J. ADAPTER

PROPOSED 4" PVC PIPE

PROPOSED 4" TRANSITION COUPLING

EXISTING 4" AC PIPE

G: \01_Proj_Current\06-25\Draw\Rev_A\Addendum_1.dwg 1-24-06 04:11:27 PM CarolC



**SOQUEL CREEK
WATER DISTRICT**

P.O. Box 158 Soquel, California 95073
Phone Number: (831) 475-8500
Fax Number: (831) 475-4291

CWO NO.
06-25

PJT. NAME: FIRE HYDRANT
INSTALLATION AT 1790 47TH AVE.

REV
A

SCALE: NONE

DWN BY: CCC

SHEET: 1 OF 1