



PROJECT SCOPE:
 HOT TAP 4-INCH MAIN TO INSTALL ONE JONES J-3740 STEAMER FIRE HYDRANT AS PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATIONS SECTION 307.05 & STD. PLANS S-9 & S-10. INSTALL THRUST BLOCK AS PER SOQUEL CREEK WATER DISTRICT STANDARD SPECIFICATION S-7. APPROXIMATE RUN: 10 FT.

EXACT FIRE HYDRANT LOCATION TO BE DETERMINED IN THE FIELD BY DISTRICT INSPECTOR PRIOR TO CONSTRUCTION.

CONTRACTOR TO CALL U.S.A. TO MARK LOCATIONS OF ALL UNDERGROUND UTILITIES PRIOR TO START OF CONSTRUCTION.

LIST OF MAJOR QUANTITIES:

- (10') 6" C900 CLASS 150 PVC PIPE
- (1) PCC THRUST BLOCK
- (1) 4" X 6" FLANGE TAPPING TEE
- (1) 6" M.J. X FLG. GATE VALVE.
- (1) CHRISTY G5 VALVE BOX AND LID
- (4') 8" SDR 35 PVC PIPE
- (1) 6" MJ HYDRANT BURY
- (1) BREAK-OFF SPOOL
- (1) JONES J-3740 FIRE HYDRANT

NO CONCRETE PAD REQUIRED - APPLICANT TO POUR SIDEWALK AFTER FIRE HYDRANT INSTALLATION.

G:\01\Proj_Current\06-25\Draw\Rev_A\A-2.dwg 1-11-06 04:39:17 PM CarolC

EXISTING		PROPOSED		LEGEND	
					UTILITY POLE MANHOLE (4' DIA. TYP.)
					STORM DRAIN INLET
					UTILITY BOX
					PROPOSED WATER MAIN (E) WATER MAIN
					4" AC

**SOQUEL CREEK
WATER DISTRICT**

P.O. Box 158 Soquel, California 95073
 Phone Number: (831) 475-8500
 Fax Number: (831) 475-4291
 DWG. NO. A-06-2152-H

CWO NO. 06-25	PJT. NAME: F.H. INSTALLATION 1790 47TH AVE., CAPITOLA	REV A
SCALE: 1"=20'	DWN BY: CCC	SHEET: 2 OF 2