



5180 SOQUEL DR.
PO BOX 158
SOQUEL, CA 95073
TEL 831-475-8500
FAX 831-475-4291

BOARD OF
DIRECTORS

BRUCE DANIELS
President
Dr. THOMAS LAHUE
Vice President

DANIEL F. KRIEGE
JOHN W. BEEBE
Dr. BRUCE JAFFE

To: **Plan Holder**

Attn.: **Bidder**

Date: **September 19, 2006**

Project: **Rio Del Mar Estates Tank
Interior Recoat**

CWO No.: **07-102**

Addendum No. 2

For the purpose of clarification please note that the contract documents for the **Rio Del Mar Estates Tank Interior Recoat** project have been changed as follows:

- The entire exterior of the tank will **not** require a full recoat. The following shall replace Section 504.21 "Exterior Surfaces – Coating Systems" The Contractor shall **completely recoat the exterior roof and upper 6-inches of wall only**, and **spot prime and recoat any remaining damaged/rusted areas as needed** of the exterior surface including, shell, ladders, railings, piping and all bare metal or broken areas. The contractor shall seat all anchor bolt nuts.

The following are three different coating systems approved by the District. All primer and finish coats shall be of one manufacturer.

TNEMEC COMPANY

Spot Prime: Series 135 Surface tolerant epoxy at 3.0-4.0 dry mils
Prime Coat: Series 135 Surface tolerant epoxy at 3.0-4.0 dry mils
Finish Coat: Series 74/75-Color Edura-Shield at 2.5-3.0 dry mils
System minimum 6.0 mils dft.

AMERON

Spot Prime: Amerlock #400 Surface tolerant epoxy at 3.0-4.0 dry mils
Primer: Amerlock #400 Surface tolerant epoxy @ 4-6 mils dft.
Finish: Amercoat Amershield aliphatic polyurethane @ 2-3 mils dft.
System minimum 6.0 mils dft.

DEVOE

Spot Prime: Bar-rust #235 Surface tolerant epoxy at 3.0-4.0 dry mils
Primer: Bar-Rust #235 Surface tolerant epoxy @ 4-8 mils dft.
Finish: Devthane 379 aliphatic gloss polyurethane @ 2-3 mils dft.
System minimum 6.0 mils dft.

BID DATE REMAINS: Tuesday, September 26, 2006 AT 2:00 PM

Please adjust bids accordingly. If you would like a hard copy of this addendum, you may pick one up at the District Office, 5180 Soquel Drive, Soquel, CA 95073.

Bidder acknowledges receipt of this addendum, which shall be attached to and made a part of the proposal.

Contractor Representative

Date

Soquel Creek Water District
Jeffery N. Gailey, PE
Engineering Manager/ Chief Engineer