



INSTALL:  
1100 ± L.F. OF 14" PVC C905, CLASS 200 WATER MAIN FROM SEACLIFF DR. @ NORTH AVE. & CENTER AVE. TO SPRECKLES DR.

APPLY:  
86,020 ± SQ. FT. CALTRANS TYPE 2 SLURRY SEAL FROM MCGREGOR DR. TO SOQUEL DR.

HOT TAP TO EXISTING 8" AC WATER MAIN

INSTALL:  
1-14"x8" FLG. TEE  
1-14" FLG. X M.J. B.V.  
1-14"x12" FLG. REDUCER  
1-12" FLG. X M.J. B.V.  
1-8" PIPE SEGMENT, LENGTH AS REQ'D  
1-8" FLG. X M.J. C.V.  
1-8" SS TAPPING SLEEVE  
1-8" RESTRAINED FLANGE COUPLING ADAPTOR  
1-TEMPORARY BLOW-OFF  
1-THRUST BLOCK PER SOWD S-7  
CONTRACTOR SHALL INSTALL ADDITIONAL FITTINGS AS NEEDED TO MAKE CONNECTION.

RECOMMENDED TEMPORARY FLUSH POINT

UNDERGROUND TELEPHONE CONDUIT. LOCATION ESTIMATED BASED ON UTILITY POLE ALIGNMENT - CONDUIT MAY FOLLOW SPRECKLES DR. CONTRACTOR TO FIELD VERIFY.

UNDERGROUND TELEPHONE CONDUIT. LOCATION ESTIMATED BASED ON UTILITY POLE ALIGNMENT - CONDUIT MAY FOLLOW SPRECKLES DR. CONTRACTOR TO FIELD VERIFY.

UNDERGROUND UTILITIES ASSOCIATED W/ POWER POLE. LOCATION UNKNOWN

No.	Revision/Issue	Date
A	ISSUED FOR REVIEW	09/12/08
0	ISSUED FOR CONSTRUCTION	10/07/08

**SEACLIFF AREA MAIN REPLACEMENT PHASE II**  
**SEACLIFF DR. AND SPRECKLES DR.**  
APTOS, SANTA CRUZ COUNTY, CALIFORNIA

APV: M/A  
G:\01\_Proj\_Current\08-42 Draw\Rev\_A-D-2\_10\_D-9.dwg 10-08-08 04:27:45 PM ccorlc

**SOQUEL CREEK WATER DISTRICT**  
PO Box 1550 Capitola, California 95010  
Phone Number: (831) 475-6500  
Fax Number: (831) 475-4291

CWO. No. 08-42  
DATE: 07/22/08  
SCALE: 1"=20'  
DESIGN BY: CCC  
DWG. NO. D-08-2173-P

Certification:  
  
Jeffery N. Gaily  
Chief Engineer  
Engineering Manager

SHEET:  
**D-8**