



1. ALL VALVE HARDWARE SHALL BE TYPE 304 STAINLESS STEEL

STD006

SOQUEL CREEK WATER DISTRICT

P.O. BOX 1550

CAPITOLA, CALIFORNIA 95010

CAD: TAD

DATE: DEC-06

CHECKED: MJW

APPROVED: JNG

BURIED VALVE ASSEMBLY

STD. NO.

S-6