



SECTION "A - A"

NOTES:

- NATIVE GROUND SHALL BE GRADED AT 2:1 (max.) FROM HYDRANT PAD
- WHERE A GRADE OF 2:1 CANNOT BE MAINTAINED, A RETAINING WALL WILL BE REQUIRED.

FILENAME

SOQUEL CREEK WATER DISTRICT

P.O. BOX 1550

CAPITOLA, CALIFORNIA 95010

CAD: TAD

DATE: DEC-06

CHECKED: MJW

APPROVED: JNG

**FIRE HYDRANT
PLACEMENT AND CLEARANCE**

STD. NO.

S-10

2/2