



5180 SOQUEL DR.
SOQUEL, CA 95073
PO Box 1550
CAPITOLA, CA 95010
TEL 831-475-8500
FAX 831-475-4291

BOARD OF DIRECTORS **To: Plan Holder Project: Granite Way Well Site
Improvements Project,
Re-Bid**

Dr. Tom Lahue
President
Dr. Bruce Daniels
Vice-President

Attn: **Bidder** CWO: **11-137**

Date: **May 3rd, 2019**

Dr. Bruce Jaffe
Carla Christensen
Rachél Lather-Hidalgo

Addendum No. 1

The contract documents for the **Granite Way Well Site Improvements Project, Re-Bid** have been changed. Please adjust bids accordingly. Staple this addendum to the original documents and special provisions.

BID DATE POSTPONED TO: May 14, 2019 at 2:00 PM

Bidder acknowledges receipt of this addendum by filling out the Addendum Receipt Table provided in Document 000300.

A handwritten signature in blue ink, appearing to read 'TAD', is written over a horizontal line.

Soquel Creek Water District
Taj Dufour, P.E.
Engineering Manager/Chief Engineer

This Addendum forms a part of the Bidding Documents and will be incorporated into Contract Documents. Insofar as the Specifications or Drawings or both are inconsistent, this Addendum governs. Acknowledge receipt of the Addendum by filling out ADDENDUM RECEIPT Table provided in Document 000300 – Bid Form. FAILURE TO DO SO WILL SUBJECT BID TO DISQUALIFICATION

For changes to contract language, strikethrough indicate existing language to be removed from contract and words in bold italics are to be inserted into contract language.

PART 1 – CHANGES/ADDITIONS TO CONTRACT DOCUMENTS

A. Contract Documents:

1. Division 0, Section 00010 Notice to Inviting Bids

The bid opening date has been POSTPONED from May 9th to May 14th.

“Notice is hereby given that sealed bids will be received by the Soquel Creek Water District in the District Office located at 5180 Soquel Dr., Soquel, CA95073 at any time prior to 2:00 PM, **May 14, 2019** for furnishing all labor, materials, equipment, and services for the construction of improvements designated...”

~~On page 00010-3 of this section – “Bidders are hereby notified that specific experience requirements must be met in order to be considered a responsive, responsible bidder. These requirements include the successful completion of at least (5) potable water public works construction projects within the public right of way over the past five (5) years. The Bidder shall complete the Certification of Experience in Section 00420 detailing the projects that fulfill these requirements. The General Contractor or their subcontractor must show they have successfully installed least three (3) PG&E services similar to the one required for the Granite Way Well Site Improvements over the past five (5) years.~~

~~The Contractor shall perform at least forty (40%) percent of the Contract Bid Amount.”~~

2. Division 0, Section 00100-3.0 Bidder’s Experience and Qualifications

This section has been REMOVED.

3. Division 0, Section 00100-17.0 Bidders Checklist

~~REMOVE Item 5: “Certification of Bidder’s Experience and Qualifications (Section 00420)” on page 00100-6.~~

~~REMOVE Item 6: “Certification of Bidders Specialty Subcontractor’s Experience and Qualifications (Section 00420A)” on page 00100-7.~~

4. Division 0, Section 00420-2.0 Certification of Bidder’s Experience and Qualifications

This section has been REMOVED.

5. Division 0, Section 00420A Certification of Bidder's Specialty Subcontractor's Experience and Qualifications

This section has been REMOVED.

C. Technical Specifications

1. Division 1, Section 02832 Fences and Gates

This section will be revised and included in Addendum 2, released the week of May 6th, 2019

PART 2 - CHANGES TO DRAWINGS

NONE

PART 3 – QUESTIONS RECEIVED

Q1 Who is required to provide the temporary fence?

A1 *See section 01560-4.1 "The existing fence on site is temporary rental fencing and the contract shall be cancelled by the District." and 01560-4.2 "Contractor shall coordinate installation of temporary fencing with the District's temporary fencing vendor to reduce the time the site is without fencing."*

Q2 Who will remove the 2 sticks of stainless-steel casing and gravel pack currently on site?

A2 *The District will be responsible for removing the material currently onsite, prior to construction.*

Q3 Does the electrical cabinet arrive powder coated?

A3 *Yes, the electrical cabinet from Control Systems West will arrive to District headquarters powder coated. It is the responsibility of the contractor to pick up and transport cabinet from district yard to job site. Specs note that any unpainted, dented, or scratched items, must be painted by the contractor.*

Q4 Who will provide the junction box at the well?

A4 *Pacific Coast Well Drilling will install the enclosure near the well head where the conduit will tie into prior to construction.*

ATTACHMENTS

PREPARED BY:

Brice Dahlmeier, Associate Engineer
Soquel Creek Water District
(831) 475-8501 ext 120
briced@soquelcreekwater.org