

Drinking Water Source Assessment Potentially Contaminating Activity Update

Water System

Soquel Creek Water District

Water Source

Main Street Well

Update Date

March, 2015

California SWRCB - DDW
Drinking Water Field Operations Branch
DDW Monterey District

District No.	05
System No.	4410017
Source No.	14
PS Code	4410017-014

Vulnerability Summary

District Name: DDW Monterey District	District No.: 05	County : Santa Cruz
System Name: Soquel Creek Water District	System No.: 4410017	
Source Name: Main Street Well	Source No.: 014	PS Code: 4410017-014

Completed by: **Hydrometrics WRI**

Date: **March 20, 2015**

THE FOLLOWING INFORMATION MUST BE INCLUDED IN THE SYSTEM CONSUMER CONFIDENCE REPORT

A source water assessment was conducted for the Main Street Well of the Soquel Creek Water District water system in March, 2015.

The source is considered most vulnerable to the following activities not associated with any detected contaminants:

- Automobile gas stations
- Chemical/petroleum processing/storage
- Automobile repair shops
- NPDES/WDR permitted discharges
- Parking lots
- Drinking water treatment plants
- High density housing
- Wells – water supply

Discussion of Vulnerability

- At gas stations, spills during filling vehicles and during filling of fuel storage tanks is a possibility that if not contained can cause contamination. Contaminants associated with operations at gas stations include oils, solvents, and miscellaneous wastes. Underground ground storage tanks at gas stations can also potentially leak. Leaks sometime take some time to detect. Contaminants associated with USTs at gas stations include diesel fuel, gasoline, and other petroleum products. The gas station identified within the Main Street well's capture zones had a historic leak that was remediated. Cleanup was approved by the regulatory agency in January 2014.
- On-site storage and use of sodium hypochlorite (12.5%) for chlorination and precipitant at the Main Street well is a potential source of contamination. The sodium hypochlorite is stored in a double contained polyethylene tank, with issued HazMat permits from the County of Santa Cruz Environmental Health Services, who perform annual inspections of the tank. Diesel for a generator at

Drinking Water Source Assessment and Protection (DWSAP) Program

the San Andreas well is stored in a tank that is inspected annually by the County of Santa Cruz Environmental Health Services.

- Automobile repair activities may result in accidental or intentional dumping of chemicals into soils. Potential contaminants include waste oils, solvents, and acids, paints. There are no reported spills associated with the repair shop within the 2-year capture zone of the well.
- NPDES discharges permitted for both the San Andreas and Bonita wells' pump to waste are identified as a PCA. The risk associated with these permitted discharge is very low because the water discharged is pumped directly from the underlying groundwater aquifer is generally high quality water.
- Emissions from exhausts, leaking hydrocarbons, and urban storm runoff are potential contaminants that could be introduced into the environment in parking lots.
- High density housing surrounding the well poses a risk to water quality from leaking sewer pipes, illegal dumping of household hazardous wastes, automotive oils and chemicals, lawn and garden products such as fertilizers, herbicides, and pesticides, and urban storm water runoff.
- Private well located within the 2-year capture zone, is a potential conduit for contamination to enter the underlying aquifers if not secured. The risk for contamination via this well is dependent on the well's sanitary seal.

A copy of the complete assessment may be viewed at:

California Department of Public Health
Drinking Water Field Operations Branch
1 Lower Ragsdale, Building 1, Suite 120
Monterey, CA 93940

You may request a summary of the assessment be sent to you by contacting:

Kim Adamson, General Manager
Soquel Creek Water District
5180 Soquel Drive
PO Box 1550
Capitola, CA 95010-1550
(831) 475-8500

Drinking Water Source Assessment and Protection (DWSAP) Program

Vulnerability Ranking - Groundwater

District Name: **DDW Monterey District** District No.: **05** County : **Santa Cruz**
 System Name: **Soquel Creek Water District** System No.: **4410017**
 Source Name: **Main Street Well** Source No.: **014** PS Code: **4410017-014**

Completed by: **Hydrometrics WRI**

Date: **March 20, 2015**

Zone	PCA (Risk Ranking)	PCA Risk Points	Zone Points	PBE Points	Vulnerability Score
		VH = 7 H = 5 M = 3 L = 1	A = 5 B5 = 3 B10 = 1 Unknown=0	L = 5 M = 3 H = 1	Risk + Zone + PBE points
A	Automobile- Gas stations (VH)	7	5	1	13
A	Chemical/petroleum processing/storage (VH)	7	5	1	13
A	Automobile- Repair shops (H)	5	5	1	11
A	NPDES/WDR permitted discharges (H)	5	5	1	11
A	Parking lots/malls (>50 spaces) (M)	3	5	1	9
A	Drinking water treatment plants (M)	3	5	1	9
A	Housing - high density (>1 house/0.5 acres) (M)	3	5	1	9
A	Wells – Water supply (M)	3	5	1	9
B10	Automobile- Gas stations (VH)	7	1	1	9
A	Schools (L)	1	5	1	7
A	Transportation Corridors- Roads/ Streets (L)	1	5	1	7
A	Surface water - streams/ lakes/rivers (L)	1	5	1	7
A	Wells – monitoring, test holes (L)	1	5	1	7
B5	Parks (M)	3	3	1	7
B5	Schools (L)	1	3	1	5
B5	USTs- Decommissioned - inactive tanks (L)	1	3	1	5
B5	USTs- Upgraded and/or registered - active tanks (L)	1	3	1	5
B5	Transportation Corridors- Roads/ Streets (L)	1	3	1	5
B5	Surface water - streams/ lakes/rivers (L)	1	3	1	5
B10	Parking lots/malls (>50 spaces) (M)	3	1	1	5
B10	Parks (M)	3	1	1	5
B10	Wells – Water supply (M)	3	1	1	5
B10	Fire stations (L)	1	1	1	3
B10	Schools (L)	1	1	1	3
B10	USTs- Decommissioned - inactive tanks (L)	1	1	1	3
B10	USTs- Upgraded and/or registered - active tanks (L)	1	1	1	3
B10	Transportation Corridors- Roads/ Streets (L)	1	1	1	3
B10	Surface water - streams/ lakes/rivers (L)	1	1	1	3

Explanation of Source Water Assessments and Definition of Terms

A source water assessment was recently completed for this drinking water source. The assessment identifies the vulnerability of the drinking water supply to contamination from typical human activities. The assessments are intended to facilitate and provide the basic information necessary for a local community to develop a program to protect the drinking water supply.

A summary of the complete assessment is provided here. For more information, contact the agency or individual that prepared the assessment (shown in summary). You may also contact the local Department of Public Health Drinking Water Field Operations Branch district office (<http://www.cdph.ca.gov/programs/Documents/DDWEM/OriginalDistrictMapCDPH.pdf>).

Additional information about assessments can be found at: <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/DWSAP.aspx>

Terms used in this summary:

Source Water Assessment: An assessment is an evaluation of a drinking water source to determine the "possible contaminating activities" (PCAs) to which the source is most vulnerable. The assessment includes: a delineation of protection zones around the source; an inventory of the types of PCAs within the source protection zones; and an analysis to determine the PCAs to which the source is most vulnerable. The information is compiled into a report that includes a map, calculations, checklists, and a summary of the findings.

Possible Contaminating Activity (PCA): A PCA is a current or historic human activity that is an actual or potential origin of contamination for a drinking water source. PCAs include activities that use, store, produce or dispose of chemicals that have the potential to contaminate drinking water supplies. There are 110 types of PCAs in the California DWSAP program.

PCA Risk Ranking: Each type of PCA is assigned a risk ranking (Very High, High, Moderate, or Low). The risk ranking is based on the contaminant(s) typically associated with that PCA, the likelihood of release from that type of facility based on historical experience, and the mobility of the contaminant(s).

PCA Inventory: The PCA inventory is a review using local knowledge, databases, and on-site evaluations to identify the occurrence and approximate location of PCAs in the source water zones. The inventory for the basic DWSAP assessments is a presence-absence review. If a type of PCA occurs in a zone, a "Yes" is noted in the inventory for that zone, regardless of whether there is one or many of that type of facility within the zone. If a PCA has been associated with a contaminant detected in the water supply, a notation is made in the PCA inventory.

Source Water Zones or Areas: These are areas located around and typically adjacent to a drinking water source that have been identified as initial protection areas.

For groundwater sources, there are typically three concentric circular zones around a source (Zones A, B5 and B10). The sizes of the are determined based on characteristics of the source. PCAs located in the inner Zone A are considered more of a risk to the water supply than PCAs located in the middle Zone B5. Similarly, PCAs located in Zone B5 are considered more of a risk than PCAs located in the outer Zone B10.

For surface water sources, the watershed is defined as the overall protection area, and as an option, zones are defined closer to the source. Two types of zones are typically established. Zone A is the area within and near the surface water body and its tributaries. Zone B is an area within 2,500 feet of the intake, not including areas in Zone A. For surface water sources, PCAs located in Zone A are considered a greater threat than PCAs located in Zone B. PCAs located on the watershed outside of the zones are considered to be of less risk to the water supply. If zones have not been defined, PCAs are considered to be of equal risk regardless of location on the watershed.

Physical Barrier Effectiveness (PBE): The PBE for a source is an evaluation of the ability of the source and the surrounding area to prevent the movement of contaminants into the source. The PBE is based on the construction and operation features of the source, and the characteristics of the surrounding area. A source is assigned a PBE of Low, Moderate or High, where High indicates that the physical barriers of the source and site are very effective in preventing the movement of contaminants. By design, typical groundwater sources will have Moderate PBE, while typical surface water sources will have Low PBE. This is due to the greater exposure of surface water sources to contamination.

Vulnerability Ranking: The vulnerability ranking is a summary of the PCAs identified in the assessment prioritized by the risk that they pose to the water supply. The prioritization is based on the risk associated with a PCA, the zone in which it occurs, and the PBE of the source. In the vulnerability ranking, points are assigned as follows:

PCA risk ranking	Very High = 7	High = 5	Moderate = 3	Low = 1	Unknown in any zone = 0
Zone (Groundwater)	A = 5	B5 = 3	B10 = 1		
Zone (Surface water with zones)	A = 5	B = 3	Watershed = 1		
Zone (Surface water without zones)	Watershed = 5				
Physical Barrier Effectiveness	Low = 5	Moderate = 3	High = 1		

The points for each type of PCA in each zone are totaled to give a vulnerability score, and the PCAs are ranked in order from the highest score to the lowest score. PCAs associated with detected contaminants are ranked at the top, regardless of vulnerability score. By definition, groundwater sources are not considered vulnerable to PCAs with scores less than 8, and surface water sources are not considered vulnerable to PCAs with scores less than 11. It should be noted that the vulnerability ranking scores do not have a direct quantitative value. Rather, the points are used only to relatively rank the types of PCAs for an individual source.

Note: Some of the summaries do not include a vulnerability ranking. If the assessment was done on paper and the details were not entered into the database, the vulnerability ranking is not available here. In addition, alternate methods of determining vulnerability were allowed in some cases, and the vulnerability ranking is not in the database.

Vulnerability Summary: The source is considered most vulnerable to the PCAs with the highest score, and to PCAs associated with detected contaminants. These PCAs are noted in the vulnerability summary. Further details or discussion may be provided in the vulnerability discussion.