

# INDOOR WATER USE EFFICIENCY CHECKLIST

## To Be Completed by Applicant

Page 1 of 2

I certify that the subject project meets the specified requirements of the Soquel Creek Indoor Water Use Efficiency Ordinance.

Signature \_\_\_\_\_

Date \_\_\_\_\_

## Project Information

Single Family    Multi-Family    Commercial    Industrial    Public    Irrigation only    Other:

Applicant Name (print): \_\_\_\_\_

Contact Phone #: \_\_\_\_\_

Project Site Address: \_\_\_\_\_

Project Area (sq.ft.): \_\_\_\_\_

# of Units: \_\_\_\_\_

# of Meters: \_\_\_\_\_

Fixture or Appliance	Requirements		Number of Devices	Project Meets Requirements
	Residential	Non-Residential		
Toilets	≤ 1.28 gpf or WaterSense	≤ 1.28 gpf or WaterSense		<input type="checkbox"/> Yes <input type="checkbox"/> No
Urinals	≤ 0.5 gpf or WaterSense	≤ 0.5 gpf or WaterSense		<input type="checkbox"/> Yes <input type="checkbox"/> No
Showers	≤ 2.0 gpm or WaterSense	≤ 2.0 gpm or WaterSense		<input type="checkbox"/> Yes <input type="checkbox"/> No
Bathroom faucets	≤ 1.5 gpm or WaterSense	≤ 0.5 gpm or ≤ 0.20 gpc		<input type="checkbox"/> Yes <input type="checkbox"/> No
Kitchen faucets	≤ 1.8 gpm	≤ 1.8 gpm		<input type="checkbox"/> Yes <input type="checkbox"/> No
Clothes washers	Energy Star Qualified	Energy Star Qualified		<input type="checkbox"/> Yes <input type="checkbox"/> No
Dishwashers	Energy Star Qualified	Energy Star Qualified		<input type="checkbox"/> Yes <input type="checkbox"/> No
Cooling towers	--	≥ 5 to 10 cycles or ≥ 2.5 LSI		<input type="checkbox"/> Yes <input type="checkbox"/> No
Food steamers	--	Boilerless or Self-Contained		<input type="checkbox"/> Yes <input type="checkbox"/> No
Ice machines	--	Energy Star Qualified		<input type="checkbox"/> Yes <input type="checkbox"/> No
Pre-rinse spray valves	--	≤ 1.1 gpm		<input type="checkbox"/> Yes <input type="checkbox"/> No
Automatic vehicle wash facilities	--	≥ 75% of the water is recycled		<input type="checkbox"/> Yes <input type="checkbox"/> No

# INDOOR WATER USE EFFICIENCY CHECKLIST

## Project Information, Continued

Page 2 of 2

Fixture or Appliance	Requirements		Number of Devices	Project Meets Requirements
	Residential	Non-Residential		
Commercial refrigeration	--	Closed loop or Air-cooled		<input type="checkbox"/> Yes <input type="checkbox"/> No
Meters	Individual meter for each unit	Individual meter for each unit		<input type="checkbox"/> Yes <input type="checkbox"/> No

## To Be Completed by Soquel Creek Water District

<p><b>Reviewer Name:</b></p> <p><b>Materials Received and Reviewed:</b></p> <p><input type="checkbox"/> Indoor Water Use Efficiency Checklist</p> <p><input type="checkbox"/> Project Plans</p> <p><b>Date Reviewed:</b></p> <p><input type="checkbox"/> Follow up required (explain):</p> <p><b>Date Resubmitted:</b></p> <p><b>Date Approved:</b></p>	<p style="text-align: center;"><b>Material Distributed to Applicant</b></p> <p><input type="checkbox"/> Indoor Water Use Efficiency Ordinance</p> <p><input type="checkbox"/> Information on qualifying fixtures and appliances</p> <p><input type="checkbox"/> Other:</p> <hr/> <p style="text-align: center;"><b>Measures Recommended to Applicant</b></p> <p><input type="checkbox"/> Hot water recirculation system</p> <p><input type="checkbox"/> Dual-plumbing for graywater</p> <p><input type="checkbox"/> Other:</p>
---	--

**Comments:**

---

**Selected Definitions:**

gpf	gallons per flush		<b>Energy Star Qualified Products:</b> <a href="http://www.energystar.gov/">www.energystar.gov/</a>
gpm	gallons per minute		
gpc	gallons per cycle		<b>WaterSense Qualified</b> <a href="http://www.epa.gov/WaterSense/">www.epa.gov/WaterSense/</a>
LSI	Langlier Saturation Index		
sq.ft.	square feet		
>	greater than		
≤	less than or equal to		
≥	greater than or equal to		